

APPENDIX E

PERRY COUNTY'S FACILITIES EVALUATIONS, FINDINGS AND PHOTOS

COUNTY-OWNED BUILDINGS

Perry County Courthouse

2219 Payne Street, Tell City, IN 47586

- County-owned facility
- Early voting location
- Construction completed in 1994
- Alterations completed in 2014

Approach & Entrance

Landing at top of curb ramps is less than 36 inches long.

Reconfigure to add a minimum 36-inch level landing at top of all curb ramps.

Access to Goods and Services

Level landing at top of ramps in meeting room is not at least 60 inches long.

Move both entry doors from original location to gain 60-inch min. clearance.

Ramps do not have handrails on both sides.

Add handrails on inside of ramp.

Handrails do not extend at least 12 inches beyond inside face of the handrail.

Alter handrails.

Door closers throughout the facility do not take at least 5 seconds to close from an open position of 90 degrees to a position of 12 degrees from the latch.

Adjust closers throughout facility.

Operable parts are higher than 48 inches above the floor.

Change height of controls.

Toilet Rooms

Door closers do not take at least 5 seconds to close from an open position of 90 degrees to a position of 12 degrees from the latch.

Adjust closers.

Water closet in restroom near auxiliary courtroom in southeast hallway should be no less than 16 inches and no greater than 18" from the side wall; Measurement: 19 inches.

Move toilet.

Grab bar is not located no more than 12 inches from the rear wall.

Relocate grab bar.

Grab bar does not extend at least 54 inches from the rear wall.

Relocate grab bar.

Additional Access

There were no noted barriers to access in this section.

Perry County Armory Annex

3214 Tell Street, Tell City, IN 47586

- County-owned facility (acquired in 2014)
- Construction completed in 1961
- Most recent alterations completed in 2017

Approach & Entrance

Parking lot with 58 total spaces has 2 accessible spaces designated. Should be 3.

Add at least 1 accessible parking space.

Door closer at West entrance does not take at least 5 seconds to close from an open position of 90 degrees to a position of 12 degrees from the latch.

Adjust closer on door.

Access to Goods and Services

Transaction counters are more than 36 inches above the floor (42 inches).

Lower section of counters.

Toilet Rooms

Door closers in restrooms in south hallway do not take at least 5 seconds to close from an open position of 90 degrees to a position of 12 degrees from the latch.

Adjust closers.

Additional Access

There were no noted barriers to access in this section.

Perry County Multi Services Building

17115 State Rd 37, Leopold, IN 47551

- County-owned facility
- Voting location
- Construction completed in 2001
- Most recent alterations completed in 2016

Approach & Entrance

There is not at least 1 van accessible parking space.

Reconfigure parking area by painting lines designating 1 accessible van space.

Accessible spaces must be at least 8' wide with an access aisle at least 5' wide.

Reconfigure parking area by painting lines designating accessible spaces.

Van accessible space must be either 11' wide with an access aisle at least 5' wide or 8' wide with an access aisle at least 8' wide.

Reconfigure one of the existing parking spaces so that it meets the minimum required widths of a van accessible space.

Access aisle is not marked.

Mark access aisles to discourage parking in them.

There is not an access aisle adjoining an accessible route to main entrance.

Install access aisle from accessible space to the main entrance.

Bottom of sign must be at least 60" above the ground.

Sign must be moved up from 46" to at least 60" above the ground.

There is no van accessible sign.

Install a van accessible sign at van accessible space.

Edges of carpet or mats must be securely attached to minimize tripping hazards.

Secure mats at edges at all accessible entrances.

Access to Goods and Services

The door hardware on door to radio communications room is not operable with one hand and/or requires tight grasping, pinching and twisting of the wrist.

Replace door hardware.

Tables in conference room are less than 28 inches above the floor.

Adjust surface height so that it is no less than 28" and no greater than 34" above floor.

Sales & Service counter does not have a portion that is no higher than 36" above floor and at least 36" long.

Lower section of entry counter.

Toilet Rooms

Operable parts of hand dryer or towel dispenser measures 53" above floor.

Operable parts above lavatories or counters must be no less than 20" and no greater than 25" deep: no higher than 44" above the floor. If not over an obstruction, no higher than 48" above the floor.

Water closet in men's restroom stall adjacent to garage area is 58" deep.

Water closet must be at least 59" deep.

Additional Access

Highest operable part of public telephone in conference room is higher than 48" above the floor.

Lower height so that it is no higher than 48" above the floor.

Telephone in conference room does not have a volume control.

Install volume control.

Volume control must be identified by a pictogram of a telephone handset with radiating sound waves.

Install pictogram.

At least one telephone should have a TTY (teletypewriter) that is at least 34" above the floor, identified by International Symbol of TTY, and signs that provide direction to the public telephone.

Install TTY at correct height and install signs.

Perry County Sheriff's Office & Detention Center

2211 Herrman Street, Tell City, IN 47586

- County-owned facility
- Construction completed in 2014

This facility was designed and constructed according to the 2010 ADA Standards.

No formal assessment was done on this facility.

Perry County South Annex

65 Park Avenue, Tell City, IN 47586

- County-owned facility (acquired in 2014)
- Construction completed in 1994
- Alterations completed in 2015

Pending facility assessment.

COUNTY-OWNED PARKS

Eagles Bluff Park and Overlook

5100 East State Road 66, Cannelton, IN 47520

- County-owned park facility (acquired in 2000)
- Voting location
- Most recent alterations completed in 2008

Approach & Entrance

Of the 2 accessible spaces, 1 van accessible parking space must be configured.

Configure 1 van accessible space.

Bottom of accessible sign is 58" above the ground.

Move sign up to at least 60" above the ground.

There is no sign reading "Van Accessible".

Install sign.

Edges of carpet or mats must be securely attached to minimize tripping hazards.

Secure mats at edges at all accessible entrances.

Access to Goods and Services

There were no noted barriers to access in this section.

Toilet Rooms

Toilet paper dispenser must be no less than 7" and no greater than 9" from the front of the water closet to the centerline of the dispenser.

Move dispenser so that middle of first roll is 7-9" from front of water closet.

Additional Access

There were no noted barriers to access in this section.

Riverside Park

Magnet, IN 47520

- County-owned park facility (acquired in 1998)
- Shelter House constructed in 1998
- Most recent alterations completed in 2016

Approach & Entrance

There is no accessible route to the shelter house.

Parking area does not have designated parking spaces.

There is no designated accessible parking space or van accessible space.

There is no marked access aisle.

There are no accessible signs with International Symbol of Accessibility.

There is no stable, firm and slip-resistant route to shelter house.

New van accessible parking space needs installed in existing parking lot.

Parking space should be a stable surface, i.e. concrete.

Parking space shall connect to an accessible path to the shelter house.

Access to Goods and Services

Not applicable.

Toilet Rooms

Not applicable.

Additional Access

Not applicable.

Wilkerson Park

Rome, IN 47574

- County-owned park facility (acquired in 1996)
- Most recent alterations completed in 2009

Approach & Entrance

There are no designated parking spaces for the public, no accessible parking spaces, no access aisles, and no signs.

Route to restroom building and shelter house are non-existent.

Surface of boat ramp is not stable, firm and slip resistant.

Ramp width of boat ramp does not extend at least 12" beyond inside face of handrail.

Access to Goods and Services

Building isn't accessible.

Toilet Rooms

Access to building does not meet code. Neither toilet rooms are accessible.

There are no tactile signs with Braille installed on push/pull side of doors.

Toilet is not less than 16" and no greater than 18" from the side wall or partition.

There is no grab bar at least 42" long installed on the side wall.

There is no grab bar at least 36" long installed on the rear wall.

Additional Access

Not applicable.

LEASED FACILITIES

Perry County Prosecutor's Office

601 Main Street, Suite C, Tell City, IN 47586

- Leased facility

Approach & Entrance

Access aisle in rear parking lot is not at least 5' wide.

Reconfigure the parking so that the access aisle is at least 5' wide.

There is no Van Accessible sign in parking area.

Install a van accessible sign at the new van accessible space.

Access to Goods and Services

Accessible route is not at least 36" wide.

Widen route.

There are no tactile signs at all permanent rooms and spaces with raised characters and Braille.

Install signage according to code.

Information counter does not have a portion that is no higher than 36" above the floor and 36" long.

Lower section of counter top.

Toilet Rooms

There are no tactile signs at toilet rooms with raised characters and Braille.

Install signage according to code.

Door closers do not take at least 5 seconds to close from an open position of 90 degrees to a position of 12 degrees from the latch.

Adjust closers.

There are no grab bars in toilet rooms.

Install all required grab bars according to code.

Flush control is not on the open side of the water closet.

Move flush control.

Doors on partitions are not self-closing.

Install closers.

Additional Access

There were no noted barriers to access in this section.

Electra Crash Memorial Site

Millstone Road, Tobinsport, IN 47520

- Leased from property owners.

Pending facility assessment.

Recycling Drop-off Site

14895 State Rd 70, Derby, IN 47514

- Leased from property owners.

Pending facility assessment.

OTHER FACILITIES

Recycling Processing Facility

508 N. 2nd and Herzeele St, Cannelton, IN 47520

- Owned by Recycling Management District

Pending facility assessment.

Recycling Drop-off Site

Old Hwy 37 & County Road 40, Branchville, IN 47514

- Owned by Recycling Management District

Pending facility assessment.

Perry County Family Practice (Health Department Immunization Clinic)

18485 State Rd 37, Leopold, IN 47551

- Owned by Perry County Memorial Hospital

Pending facility assessment.

Perry County 4-H Fairgrounds

99 Roy Fenn Drive, Cannelton, IN 47520

- Voting location

Pending facility assessment.

VOTING LOCATIONS

Bristow Community Center

20569 Huffman Road, Bristow, IN 47515

- Voting location

Pending facility assessment.

Cannelton Library

210 South 8th Street, Cannelton, IN 47520

- Voting location

Pending facility assessment.

Deer Creek Baptist Church

6733 Alamo Road, Tell City, IN 47586

- Voting location

Pending facility assessment.

3822 Mozart Street, Tell City, IN 47586

- Pending facility assessment.

1140 31st Street, Tell City, IN 47586

- Pending facility assessment.

330 Harrison Street, Troy, IN 47588

- Pending facility assessment.

1648 10th Street, Tell City, IN 47586

- Pending facility assessment.

301 Main Street, Tell City, IN 47586

- Pending facility assessment.

FINDINGS

Courthouse

- ## Armory Annex

- ## Multi Services Building

- Page 10

Prosecutor's Office

- Access aisle in rear parking lot should be at least 5' wide.
- A Van Accessible Parking sign needs to be installed.

Eagles Bluff

- One of the two accessible spaces must be configured as Van Accessible Parking space.
- Carpets or mats need removed or ADA compliant.

Riverside Park

- No accessible route to shelter house: No designated parking, no accessible parking, access aisles or signs. No stable, firm and slip-resistant route to shelter house.

Wilkerson Park

- No designated parking spaces for public parking: No accessible parking spaces, access aisles, or signs. Route to restroom building and shelter house is non-existent. Surface of boat ramp is not stable, firm, and slip resistant. Ramp width of boat ramp does not extend at least 12 inches beyond inside face of handrail.

Priority 2 Access to Goods and Services – All Facilities

Courthouse

- Level landing in meeting room is not at least 60" long.
Alternative: Entrance to meeting room from rotunda is compliant. If doors were kept open, there would not be a barrier when exiting the meeting room.
- Rails in meeting room need to be on both sides of ramp.
- Existing handrails in meeting room need to extend at least 12" beyond inside face of the handrails.
- Door closers throughout the building need adjusted.
- Height of operable parts need to be ≤48 inches above the floor.

Armory Annex

- Transaction counters (or portions of) need to be no more than 36" above floor.
Alternative: Services may also be obtained by directly entering through accessible doorways to offices. Counter heights are 42 inches. Bells placed within appropriate reach range could be used by persons in wheelchairs.

Multi Services Building

- Door hardware on door to radio communications room needs replaced. (Not operable with one hand and/or requires tight grasp, pinching and twisting of wrist.)
- Tables in conference room need to be adjusted to 28" or greater.
- Transaction counter (or portion of) needs to be no more than 36" above floor.
Alternative: Services may also be obtained by directly entering through accessible doorway to office. Counter height is 42 inches. A bell placed within appropriate reach range could be used by persons in wheelchairs.

Wilkerson Park

- Building isn't accessible.

Prosecutor's Office

- Accessible route needs to be at least 36" wide.

- Fire extinguisher in lobby area protrudes more than 4" into the path.
- No tactile signs at all permanent rooms and spaces with raised characters and Braille.
- Information counter (or portion of) needs to be no more than 36" above floor.

Alternative: Services may also be obtained by directly entering through accessible doorway to office. Counter height is 42 inches. A bell placed within appropriate reach range could be used by persons in wheelchairs. Also, the counter wall is surrounded by windows and is in the direct line of sight of the elevator, allowing staff to have direct visual contact when persons enter the office.

Priority 3 Toilet Rooms – All Facilities

Courthouse

- Door closers need adjusted.
- Water closet in restroom near auxiliary courtroom in southeast hallway needs moved, and grab bars need moved.

Comment: Accessible public restrooms are available near the entrance. Restrooms in southeast hallway have been marked so that the public is aware that they are not public restrooms.

Armory Annex

- Door closers need adjusted.

Multi Services Building

- Operable parts of hand dryer or towel dispenser needs lowered.

Eagles Bluff

- Toilet paper dispenser needs to be moved.

Riverside Park

- Not applicable.

Wilkerson Park

- Access to building and toilet rooms do not meet code.

Prosecutor's Office

- No tactile signs at toilet rooms with raised characters and Braille.
- Door closers need adjusted.
- Grab bars need installed.
- Flush control needs moved.
- Partition doors are not self-closing.

Priority 4 Additional Access – All Facilities

Multi Services Building

- Public telephone needs lowered.
- Conference room telephone does not have volume control and should be identified by pictogram
- At least one public telephone should have a TTY.

PHOTOS

COURTHOUSE


Curb ramp – from Northeast toward Entrance



Curb ramp – from Northwest toward Entrance



Meeting Room – ramps, handrails & landings (East & West entrances)



Restrooms in Southeast hallway (marked as employees only)



ARMORY ANNEX

Accessible parking and accessible routes to West & South entrances



Transaction counters – Recycling Management Office and Health Department



MULTI SERVICES BUILDING


Parking spaces



Transaction counter



Door between Radio Communication Room & EMS



Conference room tables



SOUTH ANNEX

Main entrance



Side entrance



PROSECUTOR'S OFFICE

Accessible parking area and route to entrance




Information counter (2nd Floor)



EAGLES BLUFF PARK

Accessible parking spaces and walkway to facilities



RIVERSIDE PARK

Parking area and restroom building



Outdoor shelter



Boat ramp



WILKERSON PARK

Park layout



Parking area



Shelter and restrooms; play area behind



Boat ramp

